



# **NOTES:**

SEWER SERVICE, PVC SCHEDULE 40 4" OR 6" AS SPECIFIED

2% MINIMUM SLOPE OR 12% MAXIMUM SLOPE,  $\frac{1}{4}$ " PER FOOT

ALL PIPE SHALL BEDDED IN GRANULAR BORROW 3149 B.1 OR COURSE FILTER AGGREGATE 3149H

END OF SERVICE SHALL BE 7' TO 9' DEEP AT END OF SERVICE. THE END SHALL BE A FACTORY JOINT WITH PLUG, USING A FACTORY MANUFACTURED ADAPTOR WHERE NECESSARY



LAST REVISION  
NOVEMBER 2014

## **SANITARY SEWER SERVICE**

CITY OF MAPLE GROVE ENGINEERING  
& PUBLIC WORKS DEPARTMENTS

STANDARD  
PLATE #  
SS-1